



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6080512

Culver School District	Project: General	Date Reported: 08/20/16
PO Box 259	Project #: Test 1 2016	Date Received: 08/05/16 12:15
Culver, OR 97734	Client Contact: Attn: Tony Anderson	Sampled By: Tony Anderson
370111		

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6080512-01	Sample Location: MS-111-DW-C-P									
Lead		1030	ND	mg/L	0.002	0.02	08/04/16 08:08	08/09/16	DJP	
Copper			0.057	mg/L	0.010	1.3	08/04/16 08:08	08/09/16	DJP	
6080512-02	Sample Location: MS-107-DW-C-P									
Lead		1030	ND	mg/L	0.002	0.02	08/04/16 08:06	08/09/16	DJP	
Copper			0.036	mg/L	0.010	1.3	08/04/16 08:06	08/09/16	DJP	
6080512-03	Sample Location: ES-E28-F-C-P									
Lead		1030	ND	mg/L	0.002	0.02	08/04/16 07:57	08/09/16	DJP	
Copper			0.042	mg/L	0.010	1.3	08/04/16 07:57	08/09/16	DJP	
6080512-04	Sample Location: ES-117-DW-C-P									
Lead		1030	ND	mg/L	0.002	0.02	08/04/16 07:55	08/09/16	DJP	
Copper			0.475	mg/L	0.010	1.3	08/04/16 07:55	08/09/16	DJP	
6080512-05	Sample Location: CF-142-DW-C-P									
Lead		1030	ND	mg/L	0.002	0.02	08/04/16 08:03	08/09/16	DJP	
Copper			0.057	mg/L	0.010	1.3	08/04/16 08:03	08/09/16	DJP	
6080512-06	Sample Location: CF-144-F-C-P									
Lead		1030	0.004	mg/L	0.002	0.02	08/04/16 08:01	08/09/16	DJP	
Copper			0.102	mg/L	0.010	1.3	08/04/16 08:01	08/09/16	DJP	
6080512-07	Sample Location: GM-101-DW-C-P									
Lead		1030	ND	mg/L	0.002	0.02	08/04/16 07:48	08/09/16	DJP	
Copper			0.038	mg/L	0.010	1.3	08/04/16 07:48	08/09/16	DJP	
6080512-08	Sample Location: SS-HALL-DW-C-P									
Lead		1030	ND	mg/L	0.002	0.02	08/04/16 07:50	08/09/16	DJP	
Copper			0.045	mg/L	0.010	1.3	08/04/16 07:50	08/09/16	DJP	
6080512-09	Sample Location: SS-KT-F-C-P									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6080512

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.02	08/04/16 07:52	08/09/16	DJP	
Copper			0.031	mg/L	0.010	1.3	08/04/16 07:52	08/09/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6080512

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Coding Scheme for Water Sampling

Building-Room-Device Type-Hot or Cold-Draw Type

Buildings

SS= Support Services

ES= Elementary School

MS= Middle School

HS= High School

CF= Cafeteria

GM= Gym

TF= Transportation Facility

Room

###= Room Number or label off prints

Type of Device

DW= Drinking water Bubbler

F= Faucet

Hot or Cold Water

H= Hot

C= Cold

Draw Type (Primary, Flush)

P= Primary (first draw)

F= Flush

01=first flush sample at 30 seconds

02= second flush sample at 2 minutes