

UMPQUA Research Company

626 NE Division St. - P.O. Box 609 Myrtle Creek, Oregon 97457 (541) 863-5201 Fax: (541) 863-6199

E-mail: Lab@URCmail.net Internet: http://ChemLab.cc ORELAP ID# OR100031 ANALYSIS REPORT URC # 9020108

Culver School District

PO Box 259

Culver, OR 97734

Project: General

Project #: Test 1 2019

Date Reported: 02/07/19

Date Received: 02/01/19 12:05

Sampled By:

Tony Anderson

Client Contact: Attn: Tony Anderson

Method: EPA 200.8 Matrix: Drinking Water									
	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst Qualifier
9020108-01	Sample Location: HS-28-F-C								
Lead (‡)		1030	ND	mg/L	0.002	0.02	01/31/19 06:08	02/01/19	JJL
9020108-02	Sample Location: HS-HALL-DW-C								
Lead (‡)		1030	ND	mg/L	0.002	0.02	01/31/19 06:10	02/01/19	JJL
9020108-03	Sample Location: TF-OFFICE-DW-C								
Lead (‡)		1030	ND	mg/L	0.002	0.02	01/31/19 07:13	02/01/19	JJL
9020108-04	Sample Location: 4229-KITCHEN-F-C								
Lead (‡)		1030	ND	mg/L	0.002	0.02	01/31/19 07:15	02/01/19	JJL

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609 Myrtle Creek, Oregon 97457 (541) 863-5201 Fax: (541) 863-6199

E-mail: Lab@URCmail.net

Internet: http://ChemLab.cc ORELAP ID# OR100031

ANALYSIS REPORT 9020108 URC#

Qualifiers and Definitions

DET Analyte DETECTED Analyte NOT DETECTED at or above the MRL (minimum reporting limit) ND NA Not Applicable

NR Not Reported

Sample results reported on a dry weight basis dry

RPD Relative Percent Difference MRL Minimum Reporting Limit MDL Minimum Detection Limit MCL Maximum Contamination Level **ORELAP** Accredited Analyte (‡)

Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values. (~)

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager